

Errata to
ASHRAE Guide for Sustainable Refrigerated Facilities and Refrigeration Systems
(2015)

December 10, 2019

- Page 95:** In the first paragraph, in the sentence beginning “Reduced suction line pressure...,” the compressor operating efficiency should be **2.7% to 4.5% per 1°C**, not 0.8% to 1.3% per 1°C. The Fahrenheit units are correct.
- Page 172:** The term a_w should be used in Equation 4.29 instead of a_q .
- Page 180:** The term P_a should be defined under Equation 4.48 (SI and I-P) instead of ρ_a . However, the equation and definition are otherwise correct.

For online access to these errata as well as updates to other publications, visit www.ashrae.org/publicationupdates.

Please notify ASHRAE of any other errors you might find by using the Comment on Publications form at www.ashrae.org/resources--publications.

