

**ADDENDUM**

---

Document 00910

**ADDENDUM NO. 3**

Date of Addendum: 7/31/2024

PROJECT NAME: N. Stadium IT

PROJECT NO: H-000130

BID DATE: **August 22, 2024** (There is a change to the Proposal Date.)

FROM: City of Houston, General Services Department  
900 Bagby, 2nd Floor, City Hall Annex  
Houston, Texas 77002  
Attn: Will Rios, Senior Project Manager

TO: Prospective Bidders

This Addendum forms a part of the Bid Documents and will be incorporated into the Contract, as applicable. Insofar as the original Project Manual and Drawings are inconsistent, this Addendum governs.

**CHANGE IN BID DATE**

The Proposal Date for this Project is changed from **August 8, 2024**, to **August 22, 2024**. Time of day and place for submittal of Bid remains the same.

**ADDENDUM NO. 3**

**INTRODUCTORY INFORMATION**

1. Please add the included table of content pages at the end of the table of contents in the project manual.

**BIDDING REQUIREMENTS**

1. There will be an additional non-mandatory pre-proposal meeting held on August 14, 2024 at 10:00 am in the City Hall Basement in Training Room 157. All interested bidders may attend regardless of attendance at previous pre-proposal meetings.
2. Please refer to 00210F-CSP Supplementary Instructions to Proposers for instructions to schedule a site visit.

00910-1

Addendum #3

7-29-2024

**ADDENDUM**

---

**CONTRACTING REQUIREMENTS**

1. This project is federally funded and includes a prevailing wage rate. Please refer to document 00811 Federal Wage Rate Building in the Project Manual.

**CLARIFICATIONS**

1. Demolition of existing equipment must be planned by the contractor in coordination with the building owner to avoid business interruptions. There is no current expectation regarding the order of demolition and construction. Please refer to 00210F-CSP Supplementary Instructions to Proposers to schedule a site visit to ascertain the adequacy of sleeves and conduits.
2. All doors indicated on the door schedule are new unless noted otherwise.
3. Sheet T-202, 2 LEVEL 2 - ENLARGED PLAN - TR.L2, MDF.L2: The existing rack indicated by keyed note 9 will not be demolished. Coordinate work with keyed notes 2 and 3.
4. Sheet T-202, 2 LEVEL 2 - ENLARGED PLAN - TR.L2, MDF.L2: Keyed notes 2 and 3 apply to this rack and any others where the keyed notes appear in the drawings.

**END OF ADDENDUM NO. 3**

(TRC:  DocuSigned by: Richard Vella A597721A7EB34B6... DATED: 7/31/2024)

Richard Vella  
Assistant Director  
Real Estate, Design & Construction Division  
General Services Department

SECTION 000110 – TABLE OF CONTENTS

- 1.1 DIVISION 08 – OPENINGS
  - A. DOOR HARDWARE
  
- 1.2 DIVISION 23 - HEATING, VENTILATING, AND AIR-CONDITIONING (HVAC)
  - A. 230200 - BASIC MATERIALS AND METHODS
  - B. 230300 - MECHANICAL DEMOLITION FOR REMODELING
  - C. 230513 - COMMON MOTOR REQUIREMENTS FOR HVAC EQUIPMENT
  - D. 230529 - HANGERS AND SUPPORT FOR PIPING AND EQUIPMENT - HVAC
  - E. 230553 - IDENTIFICATION FOR HVAC PIPING AND EQUIPMENT
  - F. 230593 – TESTING, ADJUSTING, AND BALANCING FOR HVAC
  - G. 230713 - DUCT INSULATION
  - H. 230716 - HVAC EQUIPMENT INSULATION
  - I. 230719 - HVAC PIPING INSULATION
  - J. 233100 - HVAC DUCTS AND CASINGS
  - K. 233300 - AIR DUCT ACCESSORIES
  - L. 233700 - AIR OUTLETS AND INLETS
  - M. 238126.13 - SMALL-CAPACITY SPLIT-SYSTEM AIR CONDITIONERS
  - N. 238146 - WATER-SOURCE UNITARY HEAT PUMPS
  
- 1.3 DIVISION 26 – ELECTRICAL
  - A. 260200 - BASIC MATERIALS AND METHODS
  - B. 260500 - COMMON WORK RESULTS FOR ELECTRICAL
  - C. 260505 - SELECTIVE DEMOLITION FOR ELECTRICAL
  - D. 260519 - LOW-VOLTAGE ELECTRICAL POWER CONDUCTORS AND CABLES
  - E. 260526 - GROUNDING AND BONDING FOR ELECTRICAL SYSTEMS
  - F. 260529 - HANGERS AND SUPPORTS FOR ELECTRICAL SYSTEMS

- G. 260533.13 - CONDUIT FOR ELECTRICAL SYSTEMS
- H. 260533.16 - BOXES FOR ELECTRICAL SYSTEMS
- I. 260553 - IDENTIFICATION FOR ELECTRICAL SYSTEMS
- J. 262200 - LOW-VOLTAGE TRANSFORMERS
- K. 263353 - UNINTERRUPTIBLE POWER SUPPLY
- L. 262416 - PANELBOARDS
- M. 262726 - WIRING DEVICES
- N. 262816.13 - ENCLOSED CIRCUIT BREAKERS
- O. 262816.16 - ENCLOSED SWITCHES
  
- 1.4 DIVISION 27 - TELECOMMUNICATIONS
  - A. 270000 – COMMUNICATIONS
  - B. 270526 - TELECOMMUNICATIONS GROUNDING AND BONDING
  - C. 270528 - INTERIOR COMMUNICATION PATHWAY
  - D. 270553 - TESTING ADMINISTRATION IDENTIFICATION
  - E. 271100 - COMMUNICATION CABINET AND EQUIPMENT ROOM
  - F. 271300 - BACKBONE AND RISER MEDIA INFRASTRUCTURE
  - G. 271500 - HORIZONTAL MEDIA INFRASTRUCTURE
  - H. 272100 - DATA COMMS AND NETWORK EQUIPMENT
  
- 1.5 DIVISION 28 – ELECTRONIC SAFETY AND SECURITY
  - A. 281300 - ACCESS CONTROL SYSTEM (ACS)
  - B. 282300 - DIGITAL VIDEO SURVEILLANCE SYSTEM (DVSS)