

**Office of the Executive Engineer (E)
IPDS Division
Room No. 1804 "A", 18th Floor,
New Delhi Municipal Council
Palika Kendra, New Delhi: 110001
Office Tel.:- 011-23340588**

CORRIGENDUM

Sub:- Supplying and laying underground 11 KV cables of size 400 sq.mm and LT cable of various sizes in NDMC area.

Tender ID:- 2017_NDMC_134724_1

Ref:- Pre-bid meeting held on dated 23/08/2017 in the office of CE(E-II), Palika Kendra, New Delhi.

S.No.	Ref Clause and page no. of NIT	As per Bid document	Amendments																		
1.	At page 1	NIT NO: NDMC/SMART GRID/2017-18/03 (2nd Call)	Be read as NIT NO: NDMC/SMART GRID/2016-17/03 (2nd Call)																		
2.	At page 2	Last date/time for receipt of tenders through e-procurement solution 04/09/2017 at 3.30PM Date/Time for opening of bid through e-procurement solution 04/09/2017 at 4.00 PM	Last date/time for receipt of tenders through e-procurement solution 08/09/2017 at 3.30PM Date/Time for opening of bid through e-procurement solution 08/09/2017 at 4.00 PM																		
3.	At page 3, column 4,6 & 7 of the table.	<table border="1" style="width: 100%;"> <thead> <tr> <th style="width: 30%;">Earnest money (Rs)</th> <th colspan="2">Date and Time</th> </tr> </thead> <tbody> <tr> <td>Rs.79,36,660/-</td> <td>Last date/time for receipt of tenders through e-procurement</td> <td>Date/time for opening of Bid through e-procurement</td> </tr> <tr> <td></td> <td>04/09/2017 upto 3:30PM</td> <td>04/09/2017 at 4:00PM</td> </tr> </tbody> </table>	Earnest money (Rs)	Date and Time		Rs.79,36,660/-	Last date/time for receipt of tenders through e-procurement	Date/time for opening of Bid through e-procurement		04/09/2017 upto 3:30PM	04/09/2017 at 4:00PM	Be read as <table border="1" style="width: 100%;"> <thead> <tr> <th style="width: 30%;">Earnest money (Rs)</th> <th colspan="2">Date and Time</th> </tr> </thead> <tbody> <tr> <td>Rs.49,68,330/-</td> <td>Last date/time for receipt of tenders through e-procurement</td> <td>Date/time for opening of Bid through e-procurement</td> </tr> <tr> <td></td> <td>08/09/2017 upto 3:30PM</td> <td>08/09/2017 at 4:00PM</td> </tr> </tbody> </table>	Earnest money (Rs)	Date and Time		Rs.49,68,330/-	Last date/time for receipt of tenders through e-procurement	Date/time for opening of Bid through e-procurement		08/09/2017 upto 3:30PM	08/09/2017 at 4:00PM
Earnest money (Rs)	Date and Time																				
Rs.79,36,660/-	Last date/time for receipt of tenders through e-procurement	Date/time for opening of Bid through e-procurement																			
	04/09/2017 upto 3:30PM	04/09/2017 at 4:00PM																			
Earnest money (Rs)	Date and Time																				
Rs.49,68,330/-	Last date/time for receipt of tenders through e-procurement	Date/time for opening of Bid through e-procurement																			
	08/09/2017 upto 3:30PM	08/09/2017 at 4:00PM																			
4.	At page 3, continue on page 4 in top line 1 & 2 (EMD)	Tender document can be viewed/downloaded from NDMC website http://govtprocurement.delhi.gov.in and the bid documents shall be uploaded on the same site by 14/08/2017 upto 04/09/2017 upto 3:30PM. Cover containing Earnest money as detailed above shall be submitted by 04/09/2017 upto 3.30 PM in the shape of demand Draft Fixed deposit receipt of a scheduled Bank in favour of The Secretary, NDMC valid for a minimum period of 3 months from the date of opening the Tender. A part of earnest money is acceptable in the form of bank guarantee also. In such case, minimum 50% of earnest money or Rs.20 lacs, whichever is less, shall have to be deposited in shape prescribed above, and balance may be deposited in shape of Bank Guarantee of any scheduled bank having validity for six months or more from the last date of receipt of bids which is to be scanned and uploaded by the intending bidders. But the bid can only be submitted after deposition of EMD in favour of Secretary NDMC in the form prescribed in NIT (Annexure – I) and uploading the mandatory scanned documents such as receipt for deposition of EMD obtained from the office of any NDMC Executive Engineer or physically deposit the original EMD in the	Be read as Tender document can be viewed/downloaded from NDMC website http://govtprocurement.delhi.gov.in and the bid documents shall be uploaded on the same site by 14/08/2017 upto 08/09/2017 upto 03:30 PM. Cover containing Earnest money as detailed above shall be submitted by 08/09/2017 upto 3.30 PM in the shape of demand Draft Fixed deposit receipt of a scheduled Bank in favour of The Secretary, NDMC valid for a minimum period of 3 months from the date of opening the Tender. A part of earnest money is acceptable in the form of bank guarantee also. In such case, minimum 50% of earnest money or Rs.20 lacs, whichever is less, shall have to be deposited in shape prescribed above, and balance may be deposited in shape of Bank Guarantee of any scheduled bank having validity for six months or more from the last date of receipt of bids which is to be scanned and uploaded by the intending bidders. But the bid can only be submitted after deposition of EMD in favour of Secretary NDMC in the form prescribed in NIT (Annexure – I) and uploading the mandatory scanned documents such as receipt for deposition of EMD obtained from the office of any NDMC Executive Engineer or physically deposit the original EMD in the																		

		<p>form prescribed before the schedule submission time of tender in the office of Executive Engineer concerned and other documents as specified. This envelope shall be opened first. In case of consortium lead bidder shall deposit the EMD. The Bid will be rejected without uploading the scanned copy of earnest money deposit receipt.</p>	<p>the form prescribed before the schedule submission time of tender in the office of Executive Engineer concerned and other documents as specified. This envelope shall be opened first. In case of consortium lead bidder shall deposit the EMD. The Bid will be rejected without uploading the scanned copy of earnest money deposit receipt.</p> <p>On the written request of bidder, detail of NDMC Bank Account shall be provided for preparation of Bank Guarantee (BG) on SMFS plate form.</p>
5.	<p>At page 4-6, clause 3(a) & page 8-10, clause C(a)</p>	<p>Should have satisfactorily completed the works as mentioned below during the last seven years ending last day of the month July 2017.</p> <p>(a). In case of original manufacturer (i.e both type of cable including 1.1 KV voltage level and 11 KV or above voltage level), must have experience of one successfully completed turnkey project in Transmission/Distribution Sector costing not less than Rs 31,74,66,403/- essentially including supply of 11 KV cables or above voltage level. Supply of 1.1 kV cables will also be considered along with 11 kV or above voltage level cables.</p> <p>In case of consortium one partner should be the original cable manufacturer of (i.e both type cable including 1.1 KV voltage level and 11 KV or above voltage level), must have experience of one successfully completed turnkey project in Transmission/ Distribution Sector costing not less than Rs. 19,26,45,440/- essentially including supply of 11 KV cables or above voltage level. Supply of 1.1 kV cables will also be considered along with 11 kV or above voltage level cables, and the other partner must have experience of one successfully completed turnkey project in Transmission/Distribution Sector costing not less than Rs 12,48,20,963/- essentially including laying of Underground Cable of 11 KV or above voltage level. Laying of Underground cables of 1.1 kV will also be considered along with underground cables of 11 kV or above voltage level.</p> <p style="text-align: center;">OR</p> <p>In case of original manufacturer (i.e both type of cable including 1.1 KV voltage level and 11 KV or above voltage level), must have experience of two successfully completed turnkey project in Transmission/Distribution Sector each costing not less than Rs 23,80,99,802/- essentially including supply of 11 KV cables or above voltage level. Supply of 1.1 kV cables will also be considered along with 11 kV or above voltage level cables.</p> <p>In case of consortium one partner should be the original cable manufacturer of (i.e both type cable including 1.1 KV voltage level and 11 KV or above voltage level), must have experience of two successfully completed turnkey project in Transmission/ Distribution Sector each costing not less than Rs. 14,44,84,080/- essentially including supply of 11 KV cables or above voltage level. Supply of 1.1 kV cables will also be considered along with 11 kV or above voltage level cables, and the other partner must have experience of two successfully completed turnkey project in Transmission/Distribution Sector each costing not less than Rs 9,36,15,722/- essentially including laying of Underground cables of 11 KV or above voltage level. Laying of underground cables of 1.1 kV will also be considered along with underground cables of 11 kV or above voltage level.</p> <p style="text-align: center;">OR</p> <p>In case of original manufacturer (i.e both type of cable including 1.1 KV voltage level and 11 KV or above voltage level), must have experience of three</p>	<p>Should have satisfactorily completed the works as mentioned below during the last seven years ending last day of the month July 2017.</p> <p>(a) In case bidder is original manufacturer of 1.1 KV cables and 11 KV or above voltage level cables, must have experience of one successfully completed turnkey project in Transmission/Distribution Sector costing not less than Rs 31,74,66,403/- essentially including supply and laying of underground 11 KV cables or above voltage level. Supply and laying of 1.1 kV cables will also be considered along with 11 kV or above voltage level cables.</p> <p>In case bidder is consortium partner, one partner should be the original cable manufacturer of (i.e both type cable including 1.1 KV voltage level and 11 KV or above voltage level), must have experience of one successfully completed work in Transmission/ Distribution Sector costing not less than Rs. 19,26,45,440/- for supply of underground 11 KV cables or above voltage level. Supply of 1.1 kV cables will also be considered along with underground 11 kV or above voltage level cables, And other partner must have experience of one successfully completed turnkey project in Transmission/Distribution Sector costing not less than Rs 12,48,20,963/- essentially including laying of Underground Cable of 11 KV or above voltage level. Laying of Underground cables of 1.1 kV will also be considered along with underground cables of 11 kV or above voltage level</p> <p style="text-align: center;">OR</p> <p>In case bidder is original manufacturer of 1.1 KV cables and 11 KV or above voltage level cables, must have experience of two successfully completed turnkey project in Transmission/Distribution Sector each costing not less than Rs 23,80,99,802/- essentially including supply and laying of underground 11 KV cables or above voltage level. Supply and laying of 1.1 kV cables will also be considered along with 11 kV or above voltage level cables.</p> <p>In case bidder is consortium partner, one partner should be the original cable manufacturer of (i.e both type cable including 1.1 KV voltage level and 11 KV or above voltage level), must have experience of two successfully completed work in Transmission/ Distribution Sector each costing not less than Rs. 14,44,84,080/- for supply of underground 11 KV cables or above voltage level. Supply of 1.1 kV cables will also be considered along with underground 11 kV or above voltage level cables, And other partner must have experience of two successfully completed turnkey project in Transmission/Distribution Sector each costing not less than Rs 9,36,15,722/- essentially including laying of Underground cables of 11 KV or above voltage level. Laying of underground cables of 1.1 kV will also be considered along with underground cables of 11 kV or above voltage level.</p> <p style="text-align: center;">OR</p> <p>In case bidder is original manufacturer of 1.1 KV cables and 11 KV or above voltage level cables, must have experience of three successfully completed turnkey project in Transmission/Distribution Sector each costing not less than</p>

	<p>successfully completed turnkey project in Transmission/Distribution Sector each costing not less than Rs 15,87,33,201/-essentially including supply of 11 KV cables or above voltage level. Supply of 1.1 kV cables will also be considered along with 11 kV or above voltage level cables.</p> <p>In case of consortium one partner should be the original cable manufacturer of (i.e both type cable including 1.1 KV voltage level and 11 KV or above voltage level), must have experience of three successfully completed turnkey project in Transmission/ Distribution Sector each costing not less than Rs. 9,63,22,720/- essentially including supply of 11 KV cables or above voltage level. Supply of 1.1 kV cables will also be considered along with 11 kV or above voltage level cables, and the other partner must have experience of three successfully completed turnkey project in Transmission/Distribution Sector each costing not less than Rs 6,24,10,481/- essentially including laying of underground cables of 11 KV or above voltage level. Laying underground cables of 1.1 kV will also be considered along with underground cables of 11 kV or above voltage level.</p> <p style="text-align: center;">AND</p> <p>1(b).In case of original manufacturer (i.e both type of cable including 1.1 KV voltage level and 11 KV or above voltage level), must have experience of one successfully completed turnkey project in Transmission/Distribution sector essentially including supply and laying of 66.15 km underground cable of 11 KV or above voltage level. Supplying & laying of 1.1 kV cables will also be considered along with underground cables of 11 kV or above voltage level, with central/state govt./central autonomous body/central public sector undertaking/PSU"s.</p> <p>In case of consortium one partner should be original cable manufacturer of (i.e both type cable including 1.1 KV voltage level and 11 KV or above voltage level), must have experience of one successfully completed turnkey project in Transmission/Distribution sector essentially for supply of 66.15km of 11 KV cables or above voltage level. Supply of 1.1 kV cables will also be considered along with 11 kV or above voltage level cables, with central/state govt./central autonomous body/central public sector undertaking/PSU"s and the other partner must have experience of one successfully completed turnkey project in Transmission/Distribution sector essentially for laying of underground cables of 66.15km of 11 KV or above voltage level. Laying of underground cables of 1.1. kV will also be considered along with 11 kV or above voltage level cables, with central/state govt./central autonomous body/central public sectorundertaking/PSU"s.</p> <p>The value of executed works shall be brought to current costing level by enhancing the actual value of work at simple rate of 7% per annum, calculated from the date of completion to last date of Receipt of application for bids.</p> <p>NOTE:</p> <p>(i) One completion certificate for two different work orders for same work shall also be considered as one turnkey project for qualifying the eligibility criteria</p> <p>(ii) For Sr. No. 1(b), bidder experience in 33 KV voltage or above voltage level cable will also be considered for calculating length of cable. In this case, the length of cables of 33 KV voltage or above voltage level shall be considered twice of the length mentioned in the completion certificate.</p>	<p>Rs 15,87,33,201/-essentially including supply and laying of underground 11 KV cables or above voltage level. Supply and laying of 1.1 kV cables will also be considered along with 11 kV or above voltage level cables.</p> <p>In case bidder is consortium partner,one partner should be the original cable manufacturer of (i.e both type cable including 1.1 KV voltage level and 11 KV or above voltage level), must have experience of three successfully completed work in Transmission/ Distribution Sector each costing not less than Rs. 9,63,22,720/- for supply of underground 11 KV cables or above voltage level. Supply of 1.1 kV cables will also be considered along with underground 11 kV or above voltage level cables, And other partner must have experience of three successfully completed turnkey project in Transmission/Distribution Sector each costing not less than Rs 6,24,10,481/- essentially including laying of underground cables of 11 KV or above voltage level. Laying of underground cables of 1.1 kV will also be considered along with underground cables of 11 kV or above voltage level.</p> <p>(b) In case bidder is original manufacturer of 1.1 KV cables and 11 KV or above voltage level cables,must have experience of one successfully completed turnkey project with central/state govt./central autonomous body/central public sector undertaking/PSU"s, costing not less than Rs. 15,87,33,201/- in Transmission/Distribution sector essentially including supply and laying of 66.15 km underground cable of 11 KV or above voltage level. Supplying & laying of 1.1 kV cables will also be considered along with underground cables of 11 kV or above voltage level,.</p> <p>In case bidder is consortium partner,One partner,should be original cable manufacturer of (i.e both type cable including 1.1 KV voltage level and 11 KV or above voltage level), must have experience of one successfully completed work with central/state govt./central autonomous body/central public sector undertaking/PSU"s in Transmission/Distribution sector, costing not less than Rs.9,63,22,720/- essentially for supply of 66.15km of 11 KV cables or above voltage level. Supply of 1.1 kV cables will also be considered along with 11 kV or above voltage level cables AND the other partner must have experience with central/state govt./central autonomous body/central public sector undertaking/PSU"s of one successfully completed turnkey project costing not less than Rs. 6,24,10,481/- in Transmission/Distribution sector essentially for laying of underground cables of 66.15km of 11 KV or above voltage level. Laying of underground cables of 1.1. kV will also be considered along with 11 kV or above voltage level cables.</p> <p>The value of executed works shall be brought to current costing level by enhancing the actual value of work at simple rate of 7% per annum, calculated from the first date of the successive month in which completion was recorded to last date of the month, previous to submission of the bid.</p> <p>NOTE:</p> <p>(i) One completion certificate for two different work orders for same work shall also be considered as one turnkey project for qualifying the eligibility criteria</p> <p>(ii) In case bidder is consortium partner, for eligibility condition mentioned at point (a) above, it is not essential to qualify the same condition by both the partner. If one partner qualifies one condition out of three and other partner qualifies the another condition w.r.t his consortium partner, shall be considered eligible for qualifying the eligible condition, mentioned at point (a) above.</p>
--	--	--

			<p>(iii) For Sr. No. 1(b), bidder experience in 33 KV voltage or above voltage level cable will also be considered for calculating length of cable. In this case, the length of cables of 33 KV voltage or above voltage level shall be considered twice of the length mentioned in the completion certificate.</p> <p>(iv) The work experience shall be evaluated on the base of both clause (a) &(b). if bidder not fulfill the eligibility criteria of any of the clause from (a) & (b), shall not be considered eligible.</p>
6.	At Page 7, Clause-11 and at page 11 Clause 3(v)	The bidder, in case of consortium, both partner shall submit in original duly signed and stamped undertaking as per Annexure A4, executed on non-judicial stamp paper worth Rs. 100/-. (To be enclosed in bid document after annexure A4)	Stands deleted.
7.	At page 7, para 7 from top & at page 11 bottom para	Bidders who have been suspended from business dealings and/or debarred and/or charge sheeted by central agencies by Power utilities/State Utility/Central utility/Central PSU/State PSU/ National/International funding agencies in any assignment/project/contract at any stage including bidding stage for obtaining the assignment/project/contract within the last three years as on the date of submission of bid shall be disqualified.	Stands deleted.
8.	At page 8, para 3 from top.	Scanned copy by 04/09/2017 upto 3:30PM.....	Be read as Scanned copy by 08/09/2017 upto 3:30PM.....
9.	At page 12, Clause-7	Last date/time for receipt of tenders though e-procurement will be stopped by TIME at 15:30 Hrs. Tenders documents, consisting of plans, specifications, the schedule of quantities of the various clauses of work to be done and the set of terms & conditions of contract to be complied with by the contractor whose tender may be accepted and other necessary documents can be seen at http://www.govtprocurement.delhi.gov.in Payment of Earnest money of Rs.79,36,660/- shall be made in the shape of Demand Draft/Fixed Deposit Receipt/Banker's Cheque of a Scheduled Bank in favour of The Secretary, N.D.M.C. payable at Delhi/New Delhi valid for a minimum period of 6 months from the date of opening the tender.	Last date/time for receipt of tenders though e-procurement will be stopped by TIME at 15:30 Hrs. Tenders documents, consisting of plans, specifications, the schedule of quantities of the various clauses of work to be done and the set of terms & conditions of contract to be complied with by the contractor whose tender may be accepted and other necessary documents can be seen at http://www.govtprocurement.delhi.gov.in Payment of Earnest money of Rs. 49,68,330/- shall be made in the shape of Demand Draft/Fixed Deposit Receipt/Banker's Cheque of a Scheduled Bank in favour of The Secretary, N.D.M.C. payable at Delhi/New Delhi valid for a minimum period of 3 months from the date of opening the tender.
10.	At Page 22, Clause-15	Single award letter /work order shall be issued for entire project. The payment shall be made to the contractor according to aggregate amount of the item, filled at the time of Bid, after deducting statutory tax and income tax, applicable at the time of release of payment. NDMC will not entertain any claim by the contractor whatsoever in respect of the same in entire project except price adjustment (for cables derived according to IEEMA for which provision has been kept in the bid document and extra/additional/substitute item as per requirement of department.) If at the time of invoicing, rerates of GST varies w.r.t. the rates of GST filled by the bidder at the time of submission of Bid, the same shall be payable/deductible from the running/final bill of the contractor	Be read as Single award letter /work order shall be issued for entire project. The payment shall be made to the contractor according to aggregate amount of the item, filled at the time of Bid, after deducting statutory tax and income tax, applicable at the time of release of payment. NDMC will not entertain any claim by the contractor whatsoever in respect of the same in entire project except price adjustment (for cables derived according to IEEMA for which provision has been kept in the bid document and extra/additional/substitute item as per requirement of department.) If at the time of invoicing, rerates of GST varies w.r.t. the rates of GST filled by the bidder at the time of submission of Bid, the same shall be payable/deductible from the running/final bill of the contractor. Road permit/way bill will not be issued for direct as well bought out item in the name of contractor.
11.	At Page 23, Clause-21	All Govt. Institute, Indian Institutes of Technology, National Institutes of Technology, Central and State Research Centers, Centrally and State funded laboratories stands approved. Contractor Executive Engineer ()	All Govt. Institute, Indian Institutes of Technology, National Institutes of Technology, Central and State Research Centers, Centrally and State funded laboratories, Any NABL laboratory which operate in accordance with ISO/IEC:17011, accredited as per ISO/IEC 17025 by Govt. body, stands approved Contractor Executive Engineer ()
12..	At Page 75-76, Clause-38	Conditions for reimbursement of levy/taxes if levied after receipt of tenders Single award letter /work order shall be issued for entire project. The payment shall be made to the contractor according to aggregate amount of the item, filled at the	A Conditions for reimbursement of levy/taxes if levied after receipt of tenders Single award letter /work order shall be issued for entire project. The payment shall be made to the contractor according to aggregate amount of the item, filled at the

		<p>time of Bid, after deducting statutory tax and income tax, applicable at the time of release of payment. NDMC will not entertain any claim by the contractor whatsoever in respect of the same in entire project except price adjustment (for cables derived according to IEEMA for which provision has been kept in the bid document and extra/additional/substitute item as per requirement of department.)</p> <p>If at the time of invoicing, rerates of GST varies w.r.t. the rates of GST filled by the bidder at the time of submission of Bid, the same shall be payable/deductible from the running/final bill of the contractor.</p>	<p>of Bid, after deducting statutory tax and income tax, applicable at the time of release of payment. NDMC will not entertain any claim by the contractor whatsoever in respect of the same in entire project except price adjustment (for cables derived according to IEEMA for which provision has been kept in the bid document and extra/additional/substitute item as per requirement of department.)</p> <p>If at the time of invoicing, rerates of GST varies w.r.t. the rates of GST filled by the bidder at the time of submission of Bid, the same shall be payable/deductible from the running/final bill of the contractor.</p> <p>Road Permit/Way Bill will not be issued by NDMC for direct transaction item between contractor and employer and for bought out item in the name of contractor.</p>
13.	At Page 90, Clause-4.1 of PRECONTRACT INTEGRITY PACT. (ANNEXURE-A1)	<p>4.Previous Transgression</p> <p>4.1 The Bidder(s)/ Contractor(s) declares that no previous transgression occurred in the last three years immediately before signing of this Integrity Pact, with any other company in any country in respect of any corrupt practices envisaged hereunder or with any Public Sector Enterprise in India or any Government Department in India that could justify BIDDER's exclusion from the tender process.</p>	<p>Be read as</p> <p>4.1 The Bidder(s)/ Contractor(s) declares that no previous transgression occurred in the last five years immediately before signing of this Integrity Pact, with any other company in any country in respect of any corrupt practices envisaged hereunder or with any Public Sector Enterprise in India or any Government Department in India that could justify BIDDER's exclusion from the tender process.</p>
14.	At page 103, ANNEXURE E-A-4	<p>(To be submitted on 100 Rs Non Judicial stamp paper)</p> <p style="text-align: center;">Annexure A4</p> <p style="text-align: center;">Undertaking by Bidder</p> <p>To, The Executive Engineer, New Delhi Municipal Council Palika Kendra, New Delhi-110001</p> <p>Project: Supplying & Laying underground 11 KV Cable of Size 400 Sq mm. and L.T cables of Various Sizes in NDMC area</p> <p>We confirm that our company <_____> as on date of the Submission of bid for Supplying & Laying underground 11 KV Cable of Size 400 Sq mm. and L.T cables of Various Sizes in NDMC area has not been suspended from business dealings and/or debarred and/or charge sheeted by central agencies, Power utilities/State Utility/Central utility/Central PSU/State PSU/National/International Funding Agencies in any assignment/Project/contract at any stage including bidding stage in last three (3) years as on date of submission of bid. I agree that NDMC may reject my bid and take suitable action against us, if our firm is found suspended from business dealings or debarred or charge sheeted by central agencies, Power utilities/State Utility/Central utility/Central PSU/State PSU/National/International Funding Agencies in any assignment/Project/contract at any stage including bidding stage for this tender.</p> <p>Sincerely,</p> <p>(Signature of the Authorized Signatory of the bidder) Name: Designation: Seal: Date: Place: Business Address:</p>	<p>Stands deleted.</p>

15.	At page 105 Clause-13	The road cut should be properly filled up with material excavated from there that should be suitably rammed and compacted so that there is no hindrance to traffic and also follow all the instructions as per the road cut permission obtained from the department/other authorities.	<p>Be read as</p> <p>It shall be the responsibility of NDMC to obtain road cut permission from the departments, e.g. NDMC, Railway, CPWD or other department.</p> <p>One copy of the road cut permission shall be handed over to the contractor to start excavation work at site, but contractor shall not be allowed before taking copy of road cut permission from department.</p> <p>The contractor shall be fully responsible for filling the open trench properly, after laying of cable, with excavated soil, rammed and compacted the excavated area to match the level of surrounding surface to avoid hindrance in smooth running of traffic / walking of pedestrian.</p> <p>The surplus Malba/ debris shall also be removed and disposed off by the contractor.</p>
16.	At page 107 Clause-23(a)	a) The routine test shall be conducted from NABL accredited lab for each lot of the cable before raising inspection call. The same shall be produced to the employer during inspection of particular Lot of cable.	<p>Be read as</p> <p>a)The routine test for HT 11 KV cable of size 400sq.mm/3 C and LT cable of all sizes shall be conducted on one sample from each lot before raising inspection call from any NABL laboratory which operate in accordance with ISO/IEC:17011, accredited as per ISO/IEC 17025 by Govt. body. The same shall be produced to the employer during inspection of particular Lot of cable.</p>
17.	At page 108 Clause-1	The Supply of Cable shall be handed over to NDMC at the stores or other places in NDMC for carrying out insulation test before laying of the cable. The contractor will then, if necessary, unroll the cable for measurement, rewind it on the drum and cart it to the site of work. He will then lay the required length of cable and return the balance to the Stores or other places in New Delhi. He will when required to do so, unroll this balance cable for measurement and rewind it on the drum. No extra amount shall be paid for this work.	<p>Be read as</p> <p>After receiving of cable from the manufacturer works, the same shall be unloaded and stored at a suitable place in NDMC area for insulation test & other measurement to release the 70% payment against delivery as per the term and condition of contract and the cable shall be handed over to the contractor for storage purpose. The watch and ward of the material shall be responsibility of the contractor. The final payments for supply of cables shall be made for the quantity actually laid at site.</p> <p>Remaining piece of 20mtrs. or above length of cables shall be retained by the department and payment shall be made against the rate for supply of cable, however remaining pieces below 20Mts length shall not be retained by NDMC and also no payment shall be made for such pieces.</p>
18.	At page 110 Clause-25	Detection/scanning of the existing underground utility services shall be in the scope of work and the contractor has to submit Ground Penetrating Radar Survey (GPRS) Report for feasibility with respect to proposed route plan for road cutting to lay their service. The report shall be certified by Authorized Signatory and self explanatory, showing feasibility with respect to proposed depth of trenchless cutting through HDD (Horizontal Directional Drilling) Method of Standard Trenchless Technology as well as for open cutting before carrying out the work.	<p>Be read as</p> <p>Contractor shall engaged an agency for Detection/scanning of the existing underground utility services and submit Ground Penetrating Radar Survey (GPRS) Report for feasibility with respect to proposed route plan for road cutting to lay their service. The report shall be certified by Authorized Signatory and self explanatory by the engaging agency, showing feasibility with respect to proposed depth of trenchless cutting through HDD (Horizontal Directional Drilling) Method of Standard Trenchless Technology as well as for open cutting before carrying out the work.</p>
19.	At page 110,new clause 31	New clause 31	<p>New clause 31</p> <p>W.e.f 01/07/2017 tax structure has been replaced with GST and there is no separate element of excise duty, DVat, Central sales Tax &service tax etc. Accordingly the GST column has been provided in the schedule of work.Bidder are requested to quote the rates after considering GST.</p>
20.	At page 110,new clause 32	New clause 32	<p>New clause 32</p> <p>The project shall be considered as a whole and undivided.</p>
21.	At page 110,new clause 33	New clause 33	<p>New clause 33</p> <p>In case of consortium, all the correspondence shall be made by the lead member of consortium.</p>

22.	At page 110, new clause 34	New clause 34	New clause 34 In case of consortium, if arbitration is preferred the same shall be between lead partner of consortium and department.
23.	At page 110, new clause 35	New clause 35	New clause 35 In case of consortium, payment will be made only to lead member of consortium.
24.	At page 111 Clause-11	Laying of new or old cables in the same trenches where cables have been dismantled.	Be read as In case cable laid for the purpose of replacement of existing cable, the new cable shall be laid in the same trench inside ESS building along with existing cables and end of the new cable left upto the existing panel. The piece of existing cable in the trench, which required no excavation, shall be removed by the contractor and same shall be deposited in the NDMC store or at the place directed by Engineer-in-Charge, after energizing the newly laid cable. Nothing extra shall be paid on this account.
25.	At page 111 Clause-12	Dismantling & relaying of cables along with same road berms or at the same site which shall be required in cases where it becomes necessary to shift the cables a few meter from the existing run in soft/hard/rocky soil.	Be read as If new cables are laid for loop in and loop out purpose with existing cable, the existing cable shall be dismantled and relaid upto a suitable place to make joint and facilitate to loop in and loop out of existing cable. In this case for dismantling and relaying of existing cable, extra payment as per prevailing rate of NDMC shall be entitled to contractor.
26.	At page 114 Clause-8	The earthing pit to lay the pipes will be dug and refilled by the contractor. The extra earth will also be removed and disposed off by the contractor.	Be read as The pit for making horizontal bore beneath the ground to lay the pipe through trenchless technology, shall be excavated and refilled by the contractor. The extra earth will also be removed and disposed off by the contractor.
27..	At page 115 Clause-C	Deduction of WCT and Labour Cess: WCT and Labour Cess shall be deducted as per prevailing rates only on cable laying work from the each running bill and final bill (Part B and Part C of price schedule).	Be read as Deduction of WCT and Labour Cess: WCT and Labour Cess as applicable at the prevailing rate at time of release of payment shall be deducted from the each running bill/ final bill.
28.	At page 119, Clause 6.1	Type Tests (For type test, certificates from CPRI / ERDA Testing Laboratories for 11 kV XLPE cable shall be submitted along with purchase order. The type test should have been conducted not later than five years on the date of supply)	Be read as The type Tests report, as mentioned in the bid document, not later than five year from the submission of bid, conducted by CPRI/ERDA/any NABL laboratory which operate in accordance with ISO/IEC:17011, accredited as per ISO/IEC 17025 by Govt. body, shall be submitted by the bidder along with bid.
29.	At page 133, Clause 16	TYPE TESTS: Type test certificates from CPRI/ ERDA Testing Laboratories for 1.1 kV XLPE, shall be submitted along with Purchase order. The Type Tests should have been conducted not later than 5 years as on the date of supply.	Be read as The type Tests report, as mentioned in the bid document, not later than five year from the submission of bid, conducted by CPRI/ERDA/ Any NABL laboratory which operate in accordance with ISO/IEC:17011, accredited as per ISO/IEC 17025 by Govt. body, shall be submitted by the bidder along with bid.

The other terms and conditions of bidding document will remain same.

Sd/-
Executive Engineer (IPDS)
Email:- eeipds.elect@ndmc.gov.in